

安全评价报告信息网上公示

| | | | | |
|------------|------------------|--|---------------|---------------------|
| 项目概况 | 项目名称 | 中国石油天然气股份有限公司甘肃嘉峪关销售分公司长城加油站安全现状评价报告 | | |
| | 行业类别 | 石油加工业；化学原料、化学品及医药制造业 | 报告提交时间 | 2022.11.25 |
| | 项目简介 | <p>中国石油天然气股份有限公司甘肃嘉峪关销售分公司长城加油站于2004年5月27日成立，位于嘉峪关市兰新西路85号，企业法定代表人为黄玉芳，该加油站的危险化学品经营许可证有效期限为2019年12月21日至2022年12月21日。许可范围：汽油、柴油、煤油。</p> <p>该加油站设置直埋地下承重卧式SF双层油罐4个，其中3个40m³汽油罐、1个50m³柴油罐，总储量为170m³，折合储量为145m³(柴油罐容积折半计算)，根据《汽车加油加气加氢站技术标准》(GB50156-2021)第3.0.9条规定属于二级加油站。</p> | | |
| 安全评价项目参与人员 | 项目评价组长 | 石青松 | 技术负责人 | 邹方永 |
| | 过程控制负责人 | 唐晓娟 | 报告编制人 | 石青松 |
| | 报告审核人 | 张会平 | 安全评价师 | 王晓华 刘全进 臧怀壮 郭晓娟 刘红岩 |
| | 注册安全工程师 | 刘全进、石青松、刘红岩、唐晓娟、张会平、邹方永 | 技术专家及技术人 员 | —— |
| 评价活动主要信息 | 安全评价类型 | 现状评价 | | |
| | 到现场开展评价工作人员 | 石青松 刘红岩 郭晓娟 | | |
| | 到现场开展评价工作时间及主要任务 | 2022.9.23，了解项目的基本情况、对现场进行勘验。 | | |

现场照片





| | | |
|--|---------|---|
| | |  A photograph of an electrical control panel. The panel is light gray and features five circuit breakers arranged horizontally. Above each breaker is a colored label with a number and some text: a yellow label with '95', a red label with '95', an orange label with '92', a black label with '98', and a green label with '0'. Each breaker has a red handle. The panel is mounted on a metal structure, and there is a yellow and black striped safety strip at the bottom. The background is a plain wall. |
| | 备注及其他信息 | 无 |